



दूरभाष/ Tele : +91-452-258 8999  
वेब/ Website : www.nhai.gov.in  
ई-मेल/ E-mail : romadurai@nhai.org  
nhairomadurai@gmail.com

भारतीय राष्ट्रीय राजमार्ग प्राधिकरण  
(सड़क परिवहन और राजमार्ग मंत्रालय)  
National Highways Authority of India  
(Ministry of Road Transport & Highways)  
क्षेत्रीय कार्यालय, मदुरै / Regional Office, Madurai  
दूसरा व तीसरी तल, विजय कृष्ण प्लाजा, संख्या-1, लेक एरिया, मेलूर मेन रोड, माट्टुतावनी, मदुरै-625 007  
2<sup>nd</sup> & 3<sup>rd</sup> Floor, Vijay Krishna Plaza, No.1, Lake Area, Melur Main Road, Mattuthavani, Madurai-625 107



NHAI/15018/4.7/2/2019/ROMadurai/957

2<sup>nd</sup> July, 2020

**INVITATION OF PUBLIC COMMENTS**

**Subject:** NHAI, Madurai Region - PIU, Tuticorin - Operation and Maintenance of 4 - laning of Madurai - Aruppukottai - Tuticorin section from Km 138/000 to Km 266/865 of NH-45B in the State of Tamil Nadu - NOC for erection of 33 KV Overhead Line from the Palampatti 33/11 KV sub-station to solar power developer M/s Ahil green energie Pvt Ltd along NH-38 - Proposal submitted - Reg.

The proposal is regarding permission for erection of 33 KV Overhead Line from the Palampatti 33/11 KV sub-station to solar power developer M/s Ahil green energie Pvt Ltd along NH-38 along the NH from Km 168/800 to Km 170/800 (RHS) in Madurai-Aruppukottai - Tuticorin section of NH-45B (New No. NH-38) was submitted to this office by the PD, PIU, Tuticorin vide letter No. NHAI/PIU/TUTY/NH-38/2020/302 dated 10.06.2020 has submitted the proposal to this office in accordance with Ministry's latest guidelines dated 22.11.2016.

2. The alignment proposed by Executive Engineer, TANGEDCO, Aruppukottai had submitted the proposal for erection of 33 KV Overhead Line along the NH from Km 168/800 to Km 170/800 (RHS) in Madurai - Aruppukottai - Tuticorin section of NH-38 in the State of Tamil Nadu i.e. in a length of 2.00 Km as detailed under:

Stretch in Km	Length (Km)	ROW (m)	Distance of Proposed Erection of 33KV Over Head line from Centre of nearest Carriageway (m)	Distance of Proposed Erection of 33KV Over Head line from Centre of line of NH (m)
<b>RHS - Erection of 33KV Over Head line</b>				
Km 168/800 to Km 170/800	2.00	60.00	21.875	28.5

3. The right of way is 60 m in the aforesaid stretch. Executive Engineer, TANGEDCO, Aruppukottai has proposed to erect 33 KV Overhead Line at the edge of the ROW for a length of 2.00 Km along National Highways. The erection of 33 KV overhead line on RSJ pole is proposed to be laid at a distance 21.875 m from the center line of the carriageway which is in conformity with Ministry's guidelines vide letter no. NHIII/ P/ 66/76 dated 19.11.1976.

C:\Users\Athipathi\Desktop\DFA.docx

4. The Executive Engineer, TANGEDCO, Aruppukottai has furnished an undertaking to the effect that they will remove the erected 33 KV overhead line in future if required by NH Authority at any time for expansion of the NH at their own cost without claiming any compensation from NHAI. Also, certified that, the proposed laying of water supply pipe line work will not affect the design, stability, traffic safety and future improvement of the proposed stretch.
5. As per the guidelines issued by the Ministry vide letter No.RW/NH-33044/29/2015/ S&R (R) dated 22.11.2016 the relaxation application submitted by the applicant will be made available for public comments and the comments will be invited within 30 days from the day of uploading.

In view of the above, comments of the public on the above proposal is invited to the below mentioned address:

The Regional Officer  
National Highways Authority of India  
No.2<sup>nd</sup> & 3<sup>rd</sup> Floor, Vijay Krishna Plaza,  
No.1, Lake Area, Melur Main Road, Mattuthavani,  
Madurai - 625 007.

Encl: As Above.

*K. Govindasamy*  
(Govindasamy K) 02/07/20 20  
Deputy General Manager (Tech.,)  
For Regional Officer

Copy to:

1. The NIC, New Delhi - for uploading in the Ministry's website.
2. PD, PIU, Tuticorin - for information